

Information documents are not authoritative. Information documents are for information purposes only and are intended to provide guidance. In the event of any discrepancy between an information document and any authoritative document¹ in effect, the authoritative document governs.

1 Purpose

This information document relates to the following authoritative document:

- Section 206.2 of the ISO rules, *Interim Supply Cushion Directives* (“Section 206.2”).

The purpose of this information document is to describe the AESO's process for the issuance of unit commitment directives under Section 206.2. This document is likely of most interest to pool participants with eligible long lead time assets as is defined in the AESO's Consolidated Authoritative Document Glossary (“CADG”).

2 Background

Section 206.2 facilitates the requirements and objectives of the *Supply Cushion Regulation*, AR 42/2024. Pool participants may also refer to the *Supply Cushion Regulation* for further guidance.

3 Estimated Cost Parameters and Physical Constraints Template

3.1 Template Details

Subsection 2 of Section 206.2 requires pool participants to submit to the AESO estimated cost parameters and physical constraints for eligible long lead time assets. Appendix 2 – *Estimated Cost Parameters and Physical Constraints Template* is the form by which pool participants are to submit these estimated cost parameters and physical constraints to the AESO.

The first sheet of the Estimated Cost Parameters and Physical Constraints Template titled “Template Inputs”, is expected to be filled and submitted to the AESO. The second sheet of the Template, titled “Cost Estimate”, can be used by a pool participant to determine estimated cost parameters and is to be submitted if requested by the AESO.

3.2 Template Terms

As laid out in the Estimated Cost Parameters and Physical Constraints Template, estimated costs and physical constraints may be split into “Hot”, “Warm” and “Cold” categories. These categories are used to identify three different start modes of the eligible long lead time asset and its associated estimated cost parameters and physical constraints characteristics. Each start mode should be identified by the length of time that the eligible long lead time asset has been offline. The “lower limit” indicates the minimum amount of time that would have elapsed following synchronization for that start-up mode of operation, in hours. Hot start mode is considered to start immediately after the eligible long lead time asset has reached 0 MW, and the lower limit is to be entered as 0 hours. Warm and cold start modes follow, with the lower limit defined by the pool participant, and are identified by a lower limit value greater than the previous start up modes.

The definitions of “Minimum Stable Generation”, “Minimum off time”, “Maximum run up time”, “Minimum on time” and “Initial start-up time”, which are inputs used in the Estimated Cost Parameters and Physical Constraints Template, can be found in the CADG.

¹ “Authoritative document” is the general name given by the AESO to categories of documents made by the AESO under the authority of the *Electric Utilities Act* and associated regulations, and that contain binding legal requirements for either market participants or the AESO, or both. Authoritative documents include the ISO rules, the reliability standards, and the ISO tariff.

The AESO also notes that the ramp rate of an eligible long lead time asset will be established using the value submitted by a pool participant in ETS under subsection 6 of Section 203.1 of the ISO rules, *Offers and Bids for Energy*.

3.3 Template Submission and Notification

A pool participant is to submit its Estimated Cost Parameters and Physical Constraints Template, including any updates, pursuant to subsection 2(3) of Section 206.2, to the AESO via email at [email address to be determined].

The AESO expects that the estimated cost parameters and physical constraints submitted in the Estimated Cost Parameters and Physical Constraints Template will represent the typical operating characteristics under normal operating conditions of the eligible long lead asset. Temporary changes for abnormal operating conditions may not require a resubmission.

The AESO will provide written notification to a pool participant, as required under subsection 2(6) of Section 206.2, via the email address used by the pool participant to submit the Estimated Cost Parameters and Physical Constraints Template.

4 Anticipated Supply Cushion Methodology

The anticipated supply cushion is a measure of energy left in the energy market merit order. The AESO calculates the anticipated supply cushion pursuant to subsection 3 of Section 206.2 and the methodology underlying its determination of the anticipated supply cushion, as set out in Appendix 1.

The AESO provides the following additional details on the methodology set out in Appendix 1:

- The estimated output from wind and solar aggregated facilities is the forecast available on the AESO wind & solar forecasting webpage, using the “most likely” forecast for both the 12-hour and 7-day forecast.
- The forecast of the net interchange is calculated by the AESO and considers actual offers, ATC limits, and fundamental variables in Alberta and surrounding jurisdictions.
- The estimated constrained down generation is calculated based on the wind and solar forecasts.

The AESO calculates the anticipated supply cushion for each settlement interval of the current day and the next 6 days. The calculation for the anticipated supply cushion is run frequently, approximately every 5 minutes for settlement intervals within the current and next day, and on an hourly basis for the remaining settlement intervals.

The Market Supply Cushion Report, available as a public “Current” report on ETS, displays the results of the anticipated supply cushion by reporting levels of market supply cushion available from 0 MW to 1000 MW+, in 200 MW increments. Further metadata information is available within the report.

5 Unit Commitment Directives

5.1 Unit Commitment Process and Determination of Directives

When the AESO determines a settlement interval where the anticipated supply cushion is below the supply cushion threshold of 932 MW, the AESO will seek to minimize the deficit by issuing directives to eligible long lead time assets to either come online, or remain online.

The AESO will issue a unit commitment directive to the least cost out-of-merit eligible long lead time asset, or combination of eligible long lead time assets, taking into account physical constraints, to minimize the supply cushion deficit for the settlement intervals identified by the AESO’s anticipated supply cushion methodology. A unit commitment directive will result in an eligible long lead time asset rejoining the dispatchable merit order and contributing its available capability to the anticipated supply cushion calculation, thereby minimizing the anticipated supply cushion deficit.

The AESO will determine what is the least cost eligible long lead time asset, or combination of eligible long lead time assets, by using both the estimated cost parameters and physical constraints submitted to the AESO by a pool participant in Appendix 1.

5.2 Timing of Instructions for a Unit Commitment Directive

For unit commitment directives requiring the eligible long lead time asset to start up at a specified time and then proceed to ramp to minimum stable generation, the instruction will be delivered prior to the initial start-up time constraint. For example, if an eligible long lead time asset with a 4-hour initial start-up time constraint is directed to synchronize by 18:00, the unit commitment directive will be delivered prior to 14:00.

While the AESO may identify a supply cushion deficit, it will not be addressed through the issuance of unit commitment directives until the times determined by the physical constraints of the eligible long lead time assets. The AESO intends to delay issuing instructions for a unit commitment directive until close to the timing determined by the initial start-up time constraint of the eligible long lead time asset receiving the unit commitment directive. The AESO will not issue unit commitment directives if the supply cushion deficit is no longer present for the settlement intervals identified by the AESO by the time the unit commitment directive instruction would otherwise need to be issued.

For unit commitment directives that require an eligible long lead time asset to remain online, the instructions for a unit commitment directive will be generated once the energy offers of the long lead time asset are out of merit and would have otherwise been dispatched to 0 MW. These instructions may be sent in real-time or prior to the top of the hour in which the eligible long lead time asset was to be subject to a 0 MW dispatch.

5.3 Delivery of Instructions for a Unit Commitment Directive

Unit commitment directives will be issued via a phone call from the AESO System Controller to the pool participant and be accompanied by an ADaMS message summarizing the instructions for a unit commitment directive. For the times that the eligible long lead time asset is to ramp up or operate due to a unit commitment directive, a corresponding “UC” dispatch instruction to the eligible long lead time asset’s minimum stable generation level will be issued through the “TMR/UC” column in ADaMS. When a unit commitment directive is over, a UC dispatch to 0 MW will be issued.

For more information regarding messages and dispatches in ADaMS, please see the *Automated Dispatch and Messaging System Participant Manual* in the help section of ADaMS.

5.4 Pool Participant Response to a Directive

In addition to Section 206.2, pool participants that receive a unit commitment directive for an eligible long lead time asset must comply with other requirements applicable to directives including subsection 3 of Section 301.2 of the ISO rules, *ISO Directives*

A unit commitment directive will not be cancelled after it is issued.

While subject to a unit commitment directive, the pool participant of the eligible long lead time asset will receive UC dispatch instructions to the asset’s minimum stable generation level. The pool participant must meet dispatch requirements as per Section 203.4, *Delivery Requirements for Energy*, during the unit commitment directive duration for any applicable UC dispatch instructions. Prior to, during, and following a unit commitment directive, the eligible long lead time asset can be dispatched or directed for energy or ancillary services.

6 Submission of Costs Being Claimed by a Pool Participant

The following information relates to pool participant obligations under subsection 6(2) of Section 206.2:

Information Document

Interim Supply Cushion Directives

ID #2024-005



- The AESO expects the written request for payment required to be submitted by a pool participant under subsection 6(2) of Section 206.2 to be in the form of an invoice that contains the information specified in subsection 6(2)(a) of Section 206.2.
- The attestation, in the form of Appendix 1 – Costs Attestation Form under Section 206.2, should only be completed and attested to by a corporate officer of the pool participant once all incremental costs related to a unit commitment directive have been incurred by the pool participant.
- The written request for payment, in the form of an invoice, and the completed attestation should be submitted at one time to the AESO via email at [email address to be determined]. Written requests for payment will not be processed without the submission of the completed attestation.
- Submission of Appendix 3 -- *Actual Incremental Costs Calculation Template* is not required unless requested by the AESO to assist in understanding the costs being claimed by the pool participant as set out in subsection 6(2)(c) of Section 206.2

Pool participants will see any payments as a result of the submissions of actual costs for unit commitment directives on the pool participant's pool statement. An ETS report detailing the payment summary for the aggregated costs associated with unit commitment directives will be populated following the processing of payments.

Appendices

Appendix 1 – *Supply Cushion Methodology*

Appendix 2 – *Estimated Cost Parameters and Physical Constraints Template*

Appendix 3 – *Actual Incremental Costs Calculation Template*

Revision History

Posting Date	Description of Changes
2024-xx-xx	Initial release.

Appendix 1

Table 1: Supply Cushion Methodology

Rule provision in Section 206.2	Nature of forecast or assessment	Calculation and methodology requirements
Subsection 3(1)	Methodology underlying the determination of the anticipated supply cushion	<p>The AESO will, at a minimum every hour, calculate the anticipated supply cushion for each settlement interval of the current day and for the 6 remaining days of the forecast scheduling period on the day preceding that current day, calculated as the sum of the following:</p> <ul style="list-style-type: none"> (a) available capability from all source assets, excluding wind and solar aggregated facilities and import assets, in Alberta with a maximum capability equal to or greater than 5 MW with an initial start-up time less than or equal to one hour or with a submitted start time at or before the period being assessed; plus (b) estimated output from wind and solar aggregated facilities; plus (c) estimated on-site generation that supplies behind-the-fence load; minus (d) minimum of forecasted net interchange or zero, where imports are a negative value and exports are priced at \$999.99 and curtailed at the top of the merit order; minus (e) the hourly forecast of Alberta Internal Load; minus (f) the AESO's estimated contingency reserve requirement that will be supplied by generators; minus (g) estimated constrained down generation.

Appendix 2 - Estimated Cost Parameters and Physical Constraints Template

Posted on the AESO website as a separate Excel workbook.

DRAFT

Appendix 3 -- *Actual Incremental Costs Calculation Template*

Posted on the AESO website as a separate Excel workbook.

DRAFT